


Software Application di6ro202 (Standard I/O)

For Input/Output Module model DI6R02 LON

Standard application status detection of digital inputs, tripping of relay outputs and data output. Application uses Standard Network Variables (SNVT) according to LonMark® prescriptions.

Application di6ro201 ID: 9F FF FF 05 00 06 04 22



Node Object

The Node Object supervises and controls the functions of the individual objects within the unit. The basic functions required by the LonMark® are supported.

Network Variables Node Object:

nviRequest

SNVT Type: SNVT_obj_request

Function: Input variable with functions RQ_NORMAL, RQ_UPDATE_STATUS and RQ_REPORT_MASK.

nvoStatus

SNVT Type: SNVT_obj_status

Function: Output variable including required status bits "invalid_id" and "invalid_request".

nviDoHeartbeat

SNVT Type: SNVT_switch

Function: If input variable is set (100.1 1), the output variables [nvoDiValue[0..5], nvoDiAllValues, nvoDoValueFb[0..1] and nvoDoAllValuesFb are updated and transmitted after a calculated period of time [Node number 1....127] x 10 ms)

Digital Input Object

Object includes status detection of digital inputs and data output.

Network Variables Digital Input Object:

nvoDiValue[0...5]

SNVT Type: SNVT_switch

Function: Status of digital inputs. The output variables are put after change of input status, expiration of heartbeat interval (nciDiHeartbeat) and module reset.

Calculated time after module reset: $1s + ([Node\ number\ 1...127] \times 10ms)$

Potential-free contact closed ==> nvoDiValue[0...5] = 100.0 1

Potential-free contract open ==> nvoDiValue[0...5] = 0.0 0

nvoDiAllValues

SNVT Type: SNVT_state

Function: Status of all digital inputs of one collective network variable. Data output analog to nvoDiValue.

Potential-free contact closed ==> nvoDiAllValues.bit[0...5] = 1

Potential-free contact open ==> nvoDiAllValues.bit[0...5] = 0

Configuration Parameter Digital Input Object:

The configuration variables are designed as bindable network variables, stored in EEPROM. Thus parameterization is also possible without installation tool.

!! The new value will be stored directly into the non-volatile memory of the hardware.

!! User must guarantee, that the total number of writing cycles does not exceed maximum

!! capacity of non-volatile memory (dimension <10000).

nciDiDebounce

SNVT Type: SNVT_count

Function: Debounce period for digital inputs (in ms). Preset value: 30 (ms).

nciDiHeartbeat

SNVT Type: SNVT_time_sec

Function: Heartbeat interval. After expiration of nciDiHeartbeat the digital inputs are polled and output variables nvoDiValue[0...3] and nvoDiAllValues are transmitted.

Heartbeat function is disabled with input values < 1 sec. (Default: 0)

Relais Output Object

Object includes functions relay control and data output.

Network Variables Relay Output Object:

nviDoValue [0...1]

SNVT Type: SNVT_switch

Function: Input variables with orders for relays (100.0 1 = ON, 0.0 0 = OFF). Each update of this network variable initiates update of respective relay output.

nviDoAllValues

SNVT Type: SNVT_state

Function: Input variable with orders for all relays.

nviDoAllValues.bit[0...1] = 0 ==> Relay = OFF

nviDoAllValues.bit[0...1] = 1 ==> Relay = ON

The variables nviDoValue and nviDoAllValues are treated the same, the last update determines relay status. Each update of this network variable initiates update of respective relay output.

nvoDoValueFb[0...1]

SNVT Type: SNVT_switch

Function: Feedback variables for switch status of relays (100.0 1 = ON, 0.0 0 = OFF). Put out after each update of input variable, expiration of heartbeat interval (nciDoHeartbeat), module reset or at reset to initial value due to timeout. Calculated period for output after module reset: 1s+([Node number 1....127] x 10ms)

nvoDoAllValuesFb:

SNVT Type: SNVT_state

Function: Feedback variables for switch status of all relays in one collective network variable. Data transmission analog to nvoDoValueFb. Path allocation like with nviDoAllValues.

Configuration Parameter Relais Output Object:

The configuration variables are designed as bindable network variables, stored in EEPROM. Thus parameterization is also possible without installation tool.

!! The new value will be stored directly into the non-volatile memory of the hardware.

!! User must guarantee, that the total number of writing cycles does not exceed maximum

!! capacity of non-volatile memory (dimension <10000).

nciDoInitAll

SNVT Type: SNVT_state

Function: Initializing switch status of relays after module reset or after expiration of nciDoTimeout. Path allocation like with nviDoAllValues. Preset value: 0 (all relays OFF).

nciDoTimeout

SNVT Type: SNVT_time_sec

Function: Monitoring period within input variable and orders for relays must be compared and updated. If this is not done in time, the relays accept the respective value from nciDoInitAll. Timeout function is disabled with input values < 1 sec. An network variable update to nviDoAllValues or one of the relay variables nviDoValue will re-start the supervising timer. Default: 0 (Timeout function disabled).

nciDoHeartbeat

SNVT Type: SNVT_time_sec

Function: Heartbeat interval. After expiration of time nciDoHeartbeat the switch statuses of relays are polled and the output variables nvoDoValueFb[0...1] and nvoDoAllValuesFb are transmitted. Heartbeat function is disabled with input values < 1 sec. (Default: 0)

Wink - Event:

Service LED is tripped and blinking two times.